

*Office Memorandum* • UNITED STATES GOVERNMENT

TO : Acting Chief, Records Management Staff

DATE: 21 August 1956

FROM : Acting Chief, Real Estate and  
Construction Division/OL

SUBJECT: Addition to Storage Building, [REDACTED]

25X1A6a

REF: Memorandum from AC/Records Management Staff to AC/RE&CD, dated  
10 August 1956

1. Your comments and recommendations noted in the reference memorandum have been reviewed and approved except for item "G". In lieu of providing vault type doors on both the basement storage room and the preservation area we are recommending one vault type door which is located at the junction of the outside platform and the corridor leading to the storage and preservation rooms. This allows one such door to accomplish the purpose of both doors you suggest. You will note there are no other areas except a toilet within the locked area. This arrangement has been agreed to by Physical Security.

2. We are directing the Architect-Engineer to incorporate your recommended changes with the above modification in the final drawings and specifications for the subject project.

25X1A9a

## Distribution:

Orig. - Addressee

1 - RE&amp;CD/Chrono

1 - RE&amp;CD/Project

25X1A9a

OL/RE&amp;CD [REDACTED] 21 Aug. '56)